

Watson-Marlow 630 Chemical Metering System

Part 1 - General

1.01 Description

- A. Chemical metering pump system shall be a complete turnkey system inclusive of all necessary fluid handling and ancillary components to ensure the reliable metering of chemical into a treatment process.
- B. The key components of this system are as follows:
 - 1. Peristaltic Chemical Metering Pump
 - 2. Calibration Column
 - 3. Pressure Relief Valve
 - 4. Discharge Pressure Gauge with Diaphragm Seal
 - 5. Fabricated HDPE Shelf with pre-piped Back Panel in one of following configurations, simplex, duplex-duty/standby, duplex-dual discharge, triplex, or quadplex.

1.02 Quality Assurance

- A. Chemical Metering System (skid) must be manufactured by the chemical metering pump manufacturer and must provide pumps and accessories as a complete turnkey system. Skids manufactured by third parties such as separate skid fabricators, pump distributors or pump representatives are not acceptable.
- B. This specification is the basis for design of peristaltic metering pumps. All pumps, whether named as an acceptable supplier or submitted as an equal must, at a minimum, meet the following critical design requirements.
 - 1. Maximum two compressing rollers for two compressions per revolution.
 - 2. Tube wall thickness of 4.0 mm and material specified.
 - 3. Large diameter spring-loaded roller set for 4.0 mm wall thickness tubing.
 - 4. Max base drive speed of 265 RPM for 4.0 mm wall thickness tubing.
 - 5. Track geometry of no less than 180 degrees and rotor geometry with roller 180 degrees apart.
 - 6. For quality assurance, all pump tubing must be manufactured by the pump manufacturer in accordance with their specifications. Tubing not manufactured by the pump manufacturer will not be acceptable.
 - 7. For chemical compatibility with a broad spectrum of chemicals, the pump housing shall have powder coating.
 - 8. Pumps to be manufacturer's standard product. Manufacturer of tubing pumps must have at least 20 operating installations in domestic water or wastewater treatment plants located in the United States over a period of at least five years in the same service and size as specified.
 - 9. Drive and pumpheads shall be 24 hr continuous duty rated and have a five-year manufacturer's warranty from date of shipment.
 - 10. Pumps must be manufactured under ISO 9001-2015.
 - 11. Pumps shall meet all applicable CE and C ETL US standards per UL61010—1:2010 and tubing must be NSF61 approved for the chemicals being pumped.
 - 12. Pumps shall be 100 % integral in design with the pumphead, motor, controls, and pump case being manufactured by the pump manufacturer themselves. All controls, motors, and gear reduction shall be housed in a single chemically resistant pump case. Pumps that require separate base plates, external gear reducers and /or gear motors, and separate controls— even if mounted on a base plate and pre-wired to the motor- are not acceptable.

1.03 Submittals

A. Submit the following:

1. Certified shop drawings.
2. Characteristic performance curve showing flow rate as a function of RPM and pressure.
3. Chemical Metering System Arrangement & Installation drawings.
4. Operating, maintenance, programming, and wiring instructions for all equipment

1.04 Delivery, Storage, & Handling

A. Shipping

1. Ship the Chemical Metering System completely assembled and ready for installation. Ship tubing separately for field installation and process line connection by contractor.
2. Pack all additional spare parts in containers bearing labels clearly designating contents and pieces of equipment for which intended.
3. Deliver spare parts at the same time as pertaining equipment. Deliver to Owner after completion of work.

B. Receiving

1. Contractor to inspect and inventory items upon delivery to site.
2. Contractor to store and safeguard equipment, material, instructions, and spare parts in accordance with manufacturer's written instructions.

Part 2 – Chemical Metering System Design

2.01 Manufacturers

- A. Watson-Marlow, Inc.

2.02 Chemical Metering System Configuration

- A. ***(Engineer to specify either Simplex, Duplex-Duty/Standby, Duplex- Dual Discharge, Triplex or Quadplex) ***

2.03 Chemical Metering System Components

A. Peristaltic Chemical Metering Pump

1. Pumps shall be positive displacement peristaltic type complete with spring-loaded pumphead, self-contained variable speed drive, and flexible extruded tube as specified.
2. Peristaltic pumping action is created by the compression of the flexible tube between the pumphead rollers and track, inducing forward fluid displacement within the tube by the rotation of the pump rotor, and subsequent vacuum-creating restitution of the tube.
3. Pumps shall be dry self-priming, capable of being run dry without damaging effects to pump or tube and shall have a maximum suction lift capability of up to 30' vertical water column. Maximum pressure rating: 30 psi
4. Pump shall not use check valves or diaphragms and shall not require dynamic seals in contact with the pumped fluid. Process fluid shall be contained within pump tubing and shall not directly contact any rotary or metallic components.
5. Flow shall be in the direction of the rotor rotation, which can be reversed and shall be proportional to rotor speed.
6. Pump Process Schedule

Quantity of Chemical Metering Systems	*(Engineer to specify)*	
Chemical Metering System Configuration	*(Engineer to specify either Simplex, Duplex-Duty/Standby, Duplex- Dual Discharge, Triplex or Quadplex)*	
Tag Number(s)	*(Engineer to specify)*	
Fluid Viscosity Specific Gravity Fluid Temperature	*(Engineer to specify)*	
Tubing Material	Marprene® *(Alternate material available upon request)*	
Max – Min Capacity (GPM)	*(Engineer to specify)*	
Max Pump RPM for Application	*(Engineer to specify)	
Tubing ID *(Engineer to specify)*	12mm	17mm
Displacement /Revolution (Gallons)	0.00974	0.01558
Min Flow Rate (GPM)	0.0010	0.0016
Max Flow Rate (GPM)	2.58	4.13
Max Discharge Pressure (PSI)	*(Engineer to specify)*	
Suction Head	*(Engineer to specify)*	
Power (VAC, Frequency, Phase)	115VAC, 60 Hz, 1 Phase	

7. Pump Construction

a. Pumphead

- 1) Pumphead shall consist of a fixed track with tool lockable-hinged guard door with secondary protection using an electrical guard switch, which shall stop the pump when the pump door is open. For operator safety, pumps without lockable guard, guard switch, and/or flip-top design pump heads are not acceptable.
- 2) Pumphead door shall have two clear windows for viewing of rotation direction. When closed, the pump head guard shall seal against the pump track for leak containment and controlled waste through the pump head waste port in the event of a tube failure. For operator and environmental safety, pumps in which the direction of rotation cannot be visually verified and/or do not have a controlled waste port are not acceptable.
- 3) Rotor assembly shall be equipped with two compression rollers, which shall be retractable for tube loading, SIP, or CIP flushing cycles. Compression rollers shall be located 180 degrees apart for compression of the tube against the track twice per rotor revolution. One roller shall at all times be fully engaged with the tubing providing complete compression to prevent backflow or siphoning. Occlusion gap shall come factory set to accommodate 4.0 mm wall thickness tube. To maximize pump efficiency, pumps without retractable rollers and/or more than 2 compressing rollers are not acceptable.
- 4) The rotor assembly shall be close coupled to the output shaft of the drive gear motor by a 19 mm keyed shaft and shall be axially secured to the shaft by a through center retaining screw.

Pumphead track shall be secured to the drive via two slotted screws and shall be self-locating.

5) Material of Construction

- a) Track: Aluminum, Trimite polyester powder coat, electrostatically applied and baked
- b) Door:
 - i. Inner Shell: Grilamid TR55
 - ii. Outer Shell: shock resistant Polyurethane
 - iii. Door Seal: Silicone
 - iv. Drain Port Adapter: Acetyl

6) Rotor:

- a) Hub & Roller Arms: Fortron 1140L4 (PPS)
- b) Hub Cover: Dupont Hytrel G5544
- c) Main Rollers: 304SS
- d) Main Roller Bearings: Carbon Steel (sealed)
- e) Guide Rollers: Nylatron
- f) Hardware & leaf springs: 304SS

b. Tubing

1. Pump shall be supplied with a LoadSure® tubing element with molded fittings, which shall be self-locating when fitted into the pumphead. Tube element shall be in contact with the inside diameter of the track (housing) through an angle of 180 degrees and be held in place on the suction and discharge by the element fittings. The tubing shall be replaceable without the use of tools and with no disassembly of the pumphead. To achieve maximum service life, pump heads with a track angle of less than 180 degrees and/or without tube elements are not acceptable.
2. Pump tubing shall be constructed of Marprene®, a thermoplastic elastomer with a 64/73 Shore A durometer and 4.0mm wall thickness. Pump manufacturer must manufacture Marprene tubing in-house. Pump manufacturers who purchase third party tubing are not acceptable.
3. Tubing must meet NSF61 for the chemical being pumped.
4. Pump shall readily accept tubing elements with ID's of 12.0mm and 17.0mm without pump adjustment or replacement. Tubing with a wall thickness less than 4.0mm is not acceptable.
5. Molded Fittings: Polypropylene, 3/4" Male Cam & Groove
6. Supply One (1) tube element of the specified size per pump.
7. Supply Two (2) one-meter long flexible reinforced PVC hoses for connection of pump to suction and discharge process lines. Flexible hose shall have a 3/4" Polypropylene female cam & groove fitting for connection to the Loadsure® Element and 3/4" Polypropylene male cam and groove fitting for connection to NPT adaptor for ease of maintenance and connection to process piping.
8. Supply Two (2) 3/4" female cam & groove to 3/4" male NPT adaptors.

c. Drive

1. Rating: Continuous 24 hour operation, 40° C ambient.

2. Supply: 110-120V 50/60 Hz and 220-240V 50/60 Hz, 1-Phase field switchable. Supply nine-foot length mains power cord with standard 115V three-prong plug.
3. Max drive power consumption: 250VA.
4. Enclosure: NEMA 4X
5. Housing: Pressure cast aluminum with Alocrom pre-treatment and exterior grade corrosion resistant polyester powder coat. By nature of the environmental conditions, unpainted housings, including 316SS are not acceptable.
6. Drive motor- brushless DC motor with integral gearbox and tachometer feedback.
 - a. Speed Control Range of 2650:1 from 0.1 to 265 rpm +/- 0.1 rpm throughout the range.
 - b. Closed loop microprocessor-controlled drive with pulse width modulation at speeds above 50 rpm and synchronous mode with magnetic field rotation control below 50 rpm.
7. Leak Detector: Pump manufacturer shall supply optical-type leak sensor mounted to the drain port of the pump head for leak detection and pump shut down in the event of a tubing failure.
8. Mounting: Drive shall be self-supporting and shall not require anchoring.

d. Manual Interface & Control

For Applications requiring Analog Process Control Engineer to specify per below:

1. Pumps must meet the following minimum requirements for operator interface functionality. Pumps not meeting this minimum functionality will not be accepted.
 - a. Display: Backlit graphical TFT Display capable of up to 8 lines of text with up to 26 characters per line to display flow rate and programming instructions. Display shall also provide visual indication of running status via screen color: Grey = Running, White = Stopped and Red = Warning.
 - b. Keypad: Keypad for start, stop, speed increment, speed decrement, forward/reverse direction, rapid prime, and programming.
 - c. Flow units: Programmable in following units: μ l/min, ml/min, ml/hr, l/min, l/hr, l/day, gallons/hr, gallons/day, g/min, kg/hr, or lb/day.
 - d. Security: Programmable keypad lock and PIN security for optional lockout of all keys except emergency stop.
 - e. Auto Restart: feature to resume pump status in the event of power outage interruption.
 - f. Multilingual menu: include programming menus in eleven languages, including at a minimum English, Spanish, and French.
 - g. Programmable "Maximum Speed" to allow operator to set the maximum speed of the pump within 0.1-265 rpm.

2. Supply auto control features to meet the following minimum functionality requirements. Pumps not meeting this minimum functionality will not be accepted.
 - a. Remote Control Inputs
 1. Speed Control:
 - a) Primary Analog 4-20mA or 0-10VDC speed input, with input signal trim able and speed scalable over any part of the drive speed range.
 - b) Provisions for alternative remote accessory potentiometer (if supplied by others)
 2. Start/Stop Control: via 5V TTL, 24V industrial logic, dry contact, or powered 110VAC contact as required per the process and instrumentation drawings- Configurable command sense allowing open to equal run or open to equal stopped.
 3. Forward/Reverse Control: via 5V TTL, 24V industrial logic, dry contact, or powered 110VAC contact as required per the process and instrumentation drawings.
 4. Auto/Man Mode Control: via 5V TTL, 24V industrial logic, dry contact, or powered 110VAC contact as required per the process and instrumentation drawings.
 5. Leak Detector Run/Stop Control: via optical style leak detector.
 - b. Status Outputs
 1. Four relay contacts rated for 30 VDC with a maximum load of 30W, NO or NC or four relay contacts rated for 130VAC as required by the process and instrumentation drawings software configurable to indicate the following:
 - a) Running/Stopped status
 - b) Forward/Reverse status
 - c) Auto/Manual status
 - d) General Alarm status
 - e) Leak Detected status
 2. Speed output –
 - a. Analog 4-20mA or 0-10 VDC
 - c. Termination: supply screw down terminals suitable for up to 18 AWG field wire and accessible through four glanded cable entry points on the pump

For Applications requiring Profibus Process Control Engineer to specify per below:

1. Pumps must meet the following minimum requirements for operator interface functionality. Pumps not meeting this minimum functionality will not be accepted.
 - a. Display: Backlit graphical TFT Display capable of up to 8 lines of text with up to 26 characters per line to

display flow rate and programming instructions.

Display shall also provide visual indication of running status via screen color: Grey = Running, White = Stopped and Red = Warning.

- b. Keypad: Keypad for start, stop, speed increment, speed decrement, forward/reverse direction, rapid prime, and programming.
 - c. Flow units: Programmable in following units: $\mu\text{l}/\text{min}$, ml/min , ml/hr , l/min , l/hr , l/day , gallons/hr, gallons/day, g/min , kg/hr , or lb/day .
 - d. Security: Programmable keypad lock and PIN security for optional lockout of all keys except emergency stop.
 - e. Auto Restart: feature to resume pump status in the event of power outage interruption.
 - f. Multilingual menu: include programming menus in eleven languages, including at a minimum English, Spanish, and French.
 - g. Programmable "Maximum Speed" to allow operator to set the maximum speed of the pump within 0.1-265 rpm.
2. Pumps must be capable of two-way digital communication over a PROFIBUS DP network with bus communication speeds from 9.6 to 12,000 kbits/s and meet the following minimum functionality requirements. All control signal features must be located internally to the pump. Pumps not meeting this minimum functionality or that require additional external control boxes with gateways are not acceptable.
- a. Control Inputs
 1. Speed Control, Start/Stop, Direction of Rotation and Flow Calibration all configurable via digital command.
 2. Leak Detector Run/Stop Control: via optical style leak detector.
 - b. Control Feedback
 1. Measured Speed, Running Status, PROFIBUS Control Enabled status, Leak Detected Status, and Current Calibration Information being utilized by the pump.
 - c. Extended Diagnostic Feedback
 1. Continuous monitoring and feedback of the following:
 - a) General Error
 - b) Motor Stalled
 - c) Over Current
 - d) Under Voltage
 - e) Over Voltage
 - f) Overload
 - g) Over Temperature

- h) Speed Error
 - i) Signal Out of Range
 - j) Over Signal
 - k) Tacho Fault
 - l) Leak Detect
- e. Spares
1. Supply four spare tube elements of the specified size per pump.
 2. Supply one spare pumphead assembly.
 - **For regular preventative maintenance and normal corrective maintenance, only tube elements need be stocked and are supplied with the pump in sufficient quantity for this purpose. For additional corrective maintenance, it is advisable to have a spare pumphead stocked.)**

For Applications requiring Ethernet Control, Engineer to specify per below:

1. Pumps must meet the following minimum requirements for operator interface functionality. Pumps not meeting this minimum functionality will not be accepted.
 - b. Display: Backlit graphical TFT Display capable of up to 8 lines of text with up to 26 characters per line to display flow rate and programming instructions. Display shall also provide visual indication of running status via screen color: Grey = Running, White = Stopped and Red = Warning.
 - c. Keypad: Keypad for start, stop, speed increment, speed decrement, forward/reverse direction, rapid prime, and programming.
 - d. Flow units: Programmable in following units: $\mu\text{l}/\text{min}$, ml/min , ml/hr , l/min , l/hr , l/day , $\text{gallons}/\text{hr}$, $\text{gallons}/\text{day}$, g/min , kg/hr , or lb/day .
 - e. Security: Programmable keypad lock and PIN security for optional lockout of all keys except emergency stop.
 - f. Auto Restart: feature to resume pump status in the event of power outage interruption.
 - g. Multilingual menu: include programming menus in eleven languages, including at a minimum English, Spanish, and French.
 - h. Programmable "Maximum Speed" to allow operator to set the maximum speed of the pump within 0.1-265 rpm.
2. Pumps must be capable of two-way digital communication over an Ethernet/IP network with baud rate of 10/100 mbps full/half duplex operation and meet the following minimum functionality requirements. All control signal features must be located internally to the pump. Pumps not meeting this minimum functionality or that require additional external control boxes with gateways are not acceptable.
 - a. Control Inputs
 1. Speed Control, Start/Stop, Direction of Rotation and Flow Calibration all configurable via digital command.
 2. Leak Detector Run/Stop Control: via optical style leak detector.
 3. Remote Pressure/Flow Sensor: via analog 4-20 mA signal
 - b. Control Feedback

1. Measured Speed, Running Status, Ethernet Control Enabled status, Leak Detected Status, Flow Totalizer, Remote Pressure, Remote Flow and Current Calibration Information being utilized by the pump.
- c. Extended Diagnostic Feedback
 1. Continuous monitoring and feedback of the following:
 - a) General Error
 - b) Motor Stalled
 - c) Over Current
 - d) Under Voltage
 - e) Over Voltage
 - f) Overload
 - g) Over Temperature
 - h) Speed Error
 - i) Signal Out of Range
 - j) Over Signal
 - k) Tacho Fault
 - l) Leak Detect

B. Calibration Columns

1. Supply Calibration Column made of clear PVC or Acrylic cylinder materials, capped both ends with ¾" thick PVC flanges with appropriately sized NPT threaded ports both top and bottom. Graduation markings shall be in fractions of gallons or milliliters in proportion to the size of the column.
2. Column shall be sized to allow a minimum 30-second draw down at maximum pump speed.

C. Pressure Relief Valve

1. Supply Pressure Relief Valve with PVC Body and PTFE/EPDM Diaphragm.
2. Relief Pressure should be adjustable from 10-150 psi.
3. Connections should be ¾" Female NPT (Socket Weld Connection also available, Engineer to Specify)

D. Discharge Gauge with Diaphragm Seal

1. Discharge Pressure Gauge shall have a 2.5" dial with a liquid filled case, stainless steel tube and socket with a pressure range of 0-100 psig.
2. Discharge Gauge shall be assembled to a Diaphragm Seal with a Teflon Diaphragm and ½" NPT PVC process connection.

E. Fabricated Polypropylene Shelf with Back Panel

1. HDPE Shelf with Back Panel shall be fabricated out ½" HDPE sheet stock. The Shelf and Back Panel shall be fusion welded together maintaining a 1" containment lip completely around the surface in which the pump sits. Metallic Shelves & Back Panels including those that are painted or coated are not acceptable.
2. All necessary piping to incorporate the above equipment into a single turnkey chemical metering system will be secured to the Shelf and Back Panel.
3. Polypropylene Shelf & Back Panel shall be designed to be either free standing or wall mounted.
4. Mounting Hardware & Installation to be supplied by the Contractor.

Part 3 – Execution

3.01 Installation (By Contractor)

- A. Contractor shall install items in accordance with manufacturer's printed instructions and as indicated and specified.
- B. Contractor to connect suction, discharge, vent and drain connections as required.
- C. Contractor shall supply shielded signal wiring for wiring of the required remote input and output to the connectors.